E-Mail/Speed-Post

कार्यालय – कार्यपालक अभियन्ता,स्वास्थ्य अनुरक्षण मण्डल (उत्तरी)
OFFICE OF THE EXECUTIVE ENGINEER (C), H.M.D. (NORTH),
लोक निर्माण विभाग (रा०रा०क्षे०दि०) P.W.D. (GNCT OF DELHI)
डा० बी०एस०ए० अस्पताल परिसर, सैक्टर–6,रोहिणी, दिल्ली
Dr. B.S.A. Hospital Complex, Sector-6, Rohini, Delhi
Phone: 011-27933260: 011-27050898.
E-mail:eepwddelhihmdn@gmail.com

सत्यमेव जयते
Goverment Of India

दिल्ली सरकार
PWD

No.: 23(NCH)/का०अभि० / स्वा०अनु०मं०(उ0) / लो०नि०वि० / 2025-26 / 2454 दिनांक: 29/11/25

सेवा में,

M/s Navair International Pvt. Ltd.
59/17, IInd floor,
Guru Ravi Das Marg
Kalkaji Extn. New Delhi-110019.

Sub : Debarment of M/s Navair International Pvt. Ltd. on account of illegal and fraudulent supply of metal fire doors in ICU Hospitals of GNCTD at Sarita Vihar, Sultan Puri, Shalimar Bagh, Chacha Nehru Bal Chikitsalaya, Guru Teg Bahadur & Raghubir Nagar.

Sir,

Whereas, the non-insulated metal fire doors were supplied by you in ICU hospitals at Sarita Vihar, Sultan Puri, Shalimar Bagh, Chacha Nehru Bal Chikitsalaya, Guru Teg Bahadur and Raghubir Nagar through the contractor M/s SAM (India) Builtwell Pvt. Ltd. in violation of mandatory safety provisions and in contravention provision contained in IS 3614:2021 and other applicable standards/codes.

Whereas, the batch stickers have been removed by you from the fire doors installed at sites of all hospitals showing your intentional act to defraud and mislead the department. Thus, the supply of non-compliant products is not only unethical but also unlawful.

Whereas, a Final Show Cause Notice was issued to you by Engineer-in-Charge vide letter no. 1793 dated 03/09/2025 providing an opportunity to explain your position within 07 (seven) days from issue of Notice as to why penal action should not be initiated against you on account of fraudulent supply of non insulated metal fire doors through M/s SAM (India) Builtwell Pvt. Ltd. in ICU Hospitals at Sarita Vihar, Sultan Puri, Shalimar Bagh, Chacha Nehru Bal Chikitsalaya, Guru Teg Bahadur & Raghubir Nagar. In reference to Show Cause Notice dated 03/09/2025 you have informed vide your letter no. nil dated 16/09/2025 (received on 18/09/2025) that "***you have received notice on 15/09/2025 through speed post and the concerned team member to handle this issue is travelling. You have further informed that this letter has been forwarded to your legal department and you will submit your reply by 15/10/2025***". The notice was also sent to you through email also on 03/09/2025. The reply has been submitted by you vide your letter dated 30/09/2025 after a lapse of 20 days from the specified time.

Whereas, you have replied in your letter that you had got work order for non-insulated metal fire doors from contractor M/s SAM (India) Builtwell Pvt. Ltd. and therefore, the supplied material was as per the purchase order placed by contractor. However, the test reports of metal fire doors state that the fire door is insulated which is in contradiction to your statement that the purchase order was placed by the contractor for non-insulated fire doors. This mismatch in test reports and actual supplied material seems to be a deliberate attempt to play with the department in convenience with the contractor.

Whereas, in view of above facts and considering your reply thoroughly, it is found that the material supplied by you for ICU Hospitals was done with intent to defraud and wilfully mislead the department & public at large thereby compromising with the public life safety in critical hospital environments.

And **whereas**, in view of the gravity of the violations, namely:

1. Supply of non-compliant and unsafe fire doors in contravention of codal provisions;
2. Destroying the evidence by way of removal of batch verification stickers from doors installed at site;
3. Fraudulent misrepresentation and breach of trust by submitting misleading documents;
4. Attempt to endanger public (patients, doctors, staff and others) safety in critical hospital environments.

This office is therefore, compelled to debar your firm M/s Navair International Pvt. Ltd. with immediate effect from participation in any works/tenders/supplies directly or indirectly in PWD, GNCTD for a minimum period of two (02) years, effective from the date of issue of this letter.

No further correspondence in this matter shall be entertained.

This issues with the approval of the competent authority.

Yours faithfully

29/11/25

(Pawan Kumar)
Executive Engineer (HMD) North
o/c PWD, GNCTD

Copy:

1) Addl. Chief Secretary, PWD GNCTD, 3rd Floor, MSO Building, New Delhi.
2) Engineer-in-Chief, PWD GNCTD, 12th Floor, MSO Building, New Delhi.
3) Pr. CE (Projects), PWD GNCTD, 9th Floor, MSO Building, New Delhi.
4) Pr. CE (M&F), PWD GNCTD, 12th Floor, MSO Building, New Delhi.
5) All CEs, SEs & EEs of PWD GNCTD.
6) PWD Website.

29/11/25

Executive Engineer (HMD) North
o/c PWD, GNCTD